

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7272-1501:133

Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

**DESIGN:** Model SC30U-3 and \*SC30DU-3 photoelectric type, 2-wire smoke detector. \*The EC30DU-3 is a potted version of Model EC30U-3 the potting material is used to prevent air leaks and is used in applications for duct detectors. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 12-30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a photoelectric type smoke detector for use with listee's separately listed compatible fire alarm control units. \*Model EC30DU-3 may be used as a duct smoke detector.

**FORMERLY:** 7272-1388:24

**XL:** 7272-1591:1355

\*Rev. 06-27-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*